



Schedule G: Risk Management Measures – Storage and Handling of Liquid Fuels

Please select (by circling Yes, No, or N/A) the measures which are in place or will be implemented (and the date) in order to manage any risk from the activity.

G1 New installations

New tanks are above ground if possible and installed in accordance with O.Reg. 217/01 and the Liquid Fuels Handling Code.

Type of Measure: Containment

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____

G2 Testing and monitoring

Storage tanks and piping are tested and monitored in accordance with Section 7 of the Liquid Fuels Handling Code.

Type of Measure: Containment

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____

G3 Dispensing

Dispensing operations are in compliance with Section 6 of the Liquid Fuels Handling Code.

Type of Measure: Containment

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____

G4 Unused tanks

Unused tanks are to be decommissioned in accordance with the Liquid Fuels Handling Code.

Type of Measure: Containment

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____

G5 Record keeping

Records of the above measures are kept and are accessible for audit if requested.

Type of Measure: Containment

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____



G6 Setback distances

Liquid fuel is stored more than 24 metres from a drilled well, watercourse or surface water feature.

Type of Measure: Spatial
 Current Practice: Yes No N/A
 Will be Implemented: Yes No N/A Implementation Date: _____

G7 Vehicle protection

Vehicle protection (i.e. bollards or equivalent) in place for tanks exposed to vehicle traffic.

Type of Measure: Contingency
 Current Practice: Yes No N/A
 Will be Implemented: Yes No N/A Implementation Date: _____

G8 Inspections

A weekly visual inspection of tanks for leaks or corrosion and weekly visual inspection of containment area are done and inspection records are kept.

Type of Measure: Contingency
 Current Practice: Yes No N/A
 Will be Implemented: Yes No N/A Implementation Date: _____

G9 Inspections

Inspected monthly by appropriate personnel and visual inspection annually by owner.

Type of Measure: Contingency
 Current Practice: Yes No N/A
 Will be Implemented: Yes No N/A Implementation Date: _____

G10 Filling procedures training

Personnel handling fuel are educated on basic filling precautions and procedures to follow for any spills during handling.

Type of Measure: Contingency
 Current Practice: Yes No N/A
 Will be Implemented: Yes No N/A Implementation Date: _____

G11 Contingency planning

There is written information and procedures to be followed in the event of a spill for business and home owners. Basic filling precautions and procedures for spills during handling are discussed. The plan should meet any applicable contingency standards.

Type of Measure: Contingency
 Current Practice: Yes No N/A
 Will be Implemented: Yes No N/A Implementation Date: _____



G12 Overfill protection device

The storage tank has an installed operational overfill protection device (i.e. tank cannot be filled >95% capacity).

Type of Measure: Contingency

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____

G13 Training of personnel

Records of employee training regarding the Risk Management Plans, and contingency plan shall be maintained and provided to the Risk Management Office upon request.

Type of Measure: Contingency

Current Practice: Yes No N/A

Will be Implemented: Yes No N/A Implementation Date: _____

Please use Schedule L, *Other Risk Management Measures*, if you wish to outline alternate measures not listed on this form.